

**SILVER VALLEY
UNIFIED SCHOOL DISTRICT**

POB 847
35320 DAGGETT-YERMO ROAD, YERMO, CA 92398



REPONSE TO RFI- ISSUE #02

REQUEST FOR PROPOSAL

**BID/RFP: #15-T101: SVUSD Structured Cabling,
eRate Public Works, Project**

March 6, 2015

RESPONSE TO RFIs:

1. Please verify that all patch cords will be owner furnished as mentioned at job walk. Please verify that the District will not be using front and rear wire management just rear WM on patch panels.
 - a. As stated in the RFP, The District will provide both Copper and Fiber patch cords. District will provide their own installation of patch cords.
2. "Schedule of Hardware/ Software/Equipment" to be submitted with bid per site. Can you clarify what is Eligible and Ineligible? We realize the new structured cabling is Eligible, but please clarify the following; **(ANSWERS IN BOLD GREEN)**
 - a. 1. Demo (Labor) of existing Metal Raceway" **Eligible** or Ineligible?
 - b. 2. Demo (Labor) of existing Cat5 Copper & Fiber Optic Cabling" **Eligible** or Ineligible?
 - c. 3. Installation (Labor & Materials) New Plastic Raceway" **Eligible** or Ineligible?
 - d. 4. Installation (Labor & Materials) New Electrical Devices in Plastic Raceway" Eligible or Ineligible? **ONLY LOW VOLTAGE IS ELIGIBLE**
 - e. 5. Installation (Labor & Materials) of Electrical Circuits to IDF's/ MDF's" Eligible or **Ineligible**
 - f. 6. Installation (Labor & Materials) of Metal Conduit Pathways for Structures Cabling. **Eligible**

END OF RFI- 02